



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published: August 7, 2019
Revised:

Public Notice ID: 19-13
Page 1 of 2

Safety Concern with Intertek Certified Product / Souci de sécurité avec le produit certifié Intertek

Goodman Company, L.P. of Houston, Texas

Notification Type:	Safety / Sécurité
Certification Type:	ETL Listed - US and Canada

Notification

Intertek notifies consumers, retailers and distributors of a potential safety concern involving the Intertek Certified products identified below. / Intertek informe les consommateurs, les détaillants et les distributeurs d'une préoccupation potentielle en matière de sécurité impliquant les produits certifiés Intertek identifiés ci-dessous.

Company Identification

Goodman Company, L.P. of Houston, Texas

Product Identification

The recalled products have model numbers beginning MBR1200AA, MBR1600AA, MBVC1600AA and MBVC2000AA, and serial numbers beginning 1704, 1705 and 1708. CPSC Recall 18-115

Hazard Involved

No incidents reported. Consumers should immediately stop using the recalled modular blowers and contact Goodman for a free inspection and to receive a new product label and electrical instructions. For any units that were installed incorrectly, Goodman will replace the wiring and/or fuse/circuit breaker protection at no cost to the consumer.

What To Do

Usage should be immediately discontinued and returned to the point of purchase. Distributors and retailers should discontinue sales and return inventories to their suppliers. / L'utilisation doit être immédiatement abandonnée et retournée au point d'achat. Les distributeurs et les détaillants devraient cesser les ventes et les stocks de retour à leurs fournisseurs.



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published: August 7, 2019
Revised:

Public Notice ID: 19-13
Page 2 of 2

Photos and Images

Link to CPSC Recall:

