



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published:
Revised:

06-Aug-24

Public Notice ID: 2024-41
Page 1 of 2

Misrepresentation of Intertek Certified Product

Halspan 90 Fire Rated Wood Door Assembly

Notification Type:	Misuse of Certification Mark
Certification Type:	Not Intertek Certified

Notification

Intertek notifies public that we have been notified by the applicant that the labels identified below have been misrepresented as Intertek Certified.

Company Identification

Techno Wood Factory

Product Identification

For misrepresentation of certified product labels. Photos on Page 2

Client name: Techno Wood Factory
 Client Address: P.O. Box 2003, Dallah Industrial Area, Dammam, Kingdom of Saudi Arabia
 Project Name: New Compartmentalization Doors (Supplier: Prime Arabia Contracting Co. Ltd., Dahrhan)
 WN Number: 24256
 Label numbers: from 000004 to 000011
 Label Qty: 8
 Label Description: Halspan 90 Fire Rated Wood Door Assembly

Hazard Involved

Not Intertek Certified

What To Do

Use should be immediately discontinued and return to the point of purchase and the labels should be removed and returned to Intertek.



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667

intertek.com

Published: August 6, 2024

Revised:

Public Notice ID: 2024-41

Page 2 of 2

Photos and Images

